

1 BILL NO. S-89-03-20

2 SPECIAL ORDINANCE NO. S-

*Withdrawn*

3 AN ORDINANCE approving the awarding of  
4 Reference #003480 by the City of Fort  
5 Wayne, Indiana, by and through its  
6 Department of Purchasing and JOHN DEHNER  
for the Water Pollution Control  
Maintenance Department.


7 NOW, THEREFORE, BE IT ORDAINED BY THE COMMON COUNCIL OF  
8 THE CITY OF FORT WAYNE, INDIANA;

9 SECTION 1. That Reference #003480 between the City of  
10 Fort Wayne, by and through its Department of Purchasing and  
11 JOHN DEHNER for the Water Pollution Control Maintenance  
12 Department, respectfully for:


13 a manhole and sewer line replacement  
14 starting at wet well of the lift station  
at Engle and Clubview;

15 involving a total cost of Forty-Nine Thousand Eight Hundred  
16 Forty and no/100 Dollars (\$49,840.00), all as more  
17 particularly set forth in said Reference #003480 which is  
18 on file in the Office of the Department of Purchasing, and  
19 is by reference incorporated herein, made a part hereof, and  
20 is hereby in all things ratified, confirmed and approved.

21 SECTION 2. That this Ordinance shall be in full force  
22 and effect from and after its passage and any and all  
23 necessary approval by the Mayor.

24   
25 Councilmember

26 APPROVED AS TO FORM  
27 AND LEGALITY

28  
29   
30 J. Timothy McCaulay, City Attorney  
31  
32



REF NO.: 003480

DEPT.: WPC MAINTENANCE

DATE: 03/13/89

ITEM/SERV.: MANHOLE & SEWER LINE REPLACEMENT

PURCHASING INFORMATION

ADVERTISED BID: NO

DATES ADVERTISED:

OPENING DATE:

WRITTEN QUOTE: YES

DUE DATE: 12/05/88

VERBAL QUOTE:

NO. OF VENDORS NOTIFIED: 8

NO. OF VENDORS REQUESTING BID INFO: 8

NO. OF VENDORS RESPONDING: 3

NO. OF VENDORS DISQUALIFIED:

NO. OF VENDORS NOT RESPONDING: 5

DATE SENT TO DEPT. FOR RECOMMENDATION: 12/07/88

DATE RECOMMENDATION REC'D IN PURCHASING: 03/10/89

DATE INFO SENT TO LAW DEPT.: 03/20/89

INTRODUCTION DATE: 03/28/89

DISCUSSION DATE:

PASSAGE DATE:

ORDINANCE NO.:

AMOUNT APPROVED AND/OR SPENT LAST YEAR:  
(IF APPLICABLE)

REFERENCE NO. 3480  
WPC MAINTENANCE  
MANHOLE

T & G EXC	\$17,130.00
BERCOT	\$65,482.00
JOHN DEHNER	\$49,840.00

BILL, PLEASE REVIEW AND RETURN YOUR RECOMMENDATION IN WRITING TO ME.  
THANKS, PATTY JEAN.



PLEASE INDICATE THIS NUMBER  
ON ALL CORRESPONDENCE

QUOTE NO. 003480

#### Quotations

 Sealed Bids

WILL BE RECEIVED AT  
THIS OFFICE UNTIL

12/05/88 - 4:00 P.M.

PAGE

The Contractor and his sub-contractors, if any, shall not discriminate against any employee or applicant for employment, to be employed in the performance of this contract, with respect to his hire, tenure, conditions or privileges of employment or any matter directly or indirectly related to employment, because of his race, color, religion, national origin or ancestry. Breach of this covenant may be regarded as a material breach of the contract.

**REQUEST FOR QUOTATION  
THIS IS NOT AN ORDER**

PLEASE QUOTE BELOW LOWEST PRICES, WHICH **MUST** INCLUDE ALL DELIVERY CHARGES (INCLUDING FREIGHT, PARCEL POST AND EXPRESS) UNLESS OTHERWISE SPECIFIED, FOR PURCHASING MERCHANDISE OR SERVICE DESCRIBED BELOW.

QUOTATIONS WILL BE OPENED IN ACCORDANCE TO RULES  
AND REGULATIONS ON THE REVERSE SIDE OF THIS SHEET.  
RESPECTFULLY.

Charles Graham

RECEIVED  
1988 DEC -5 PM 2:47  
PURCHASING

THIS IS ONLY AN INVITATION TO QUOTE AND NOT AN ORDER. THE ABOVE QUOTES ARE SUBMITTED IN ACCORDANCE WITH THE REGULATIONS ON THE REVERSE SIDE OF THIS SHEET.

SIGNATURE OF BIDDER:

Gregory Denner, Vice President

DATE: December 5, 1988

**VENDOR 3**



**REQUEST FOR QUOTATION**  
**City of Fort Wayne**  
**DEPARTMENT OF PURCHASES**  
 NUMBER ONE EAST MAIN STREET ROOM 350  
 FORT WAYNE, IN 46802

PLEASE INDICATE THIS NUMBER  
ON ALL CORRESPONDENCE

QUOTE NO. **00 3480**

DATE OF REQUEST  
**11/16/88**

☐ Quotations

☐ Sealed Bids

WILL BE RECEIVED AT  
THIS OFFICE UNTIL


**RECEIVED NOV 17 1988 4:00 P.M.**

PAGE



TO

**BERCOT-GIBSON**  
**6015 HUGUENARD RD**  
**FORT WAYNE IN 46818**



The Contractor and his sub-contractors, if any, shall not discriminate against any employee or applicant for employment, to be employed in the performance of this contract, with respect to his hire, tenure, conditions or privileges of employment or any matter directly or indirectly related to employment, because of his race, color, religion, national origin or ancestry. Breach of this covenant may be regarded as a material breach of the contract.

**REQUEST FOR QUOTATION**  
**THIS IS NOT AN ORDER**

PLEASE QUOTE BELOW LOWEST PRICES, WHICH MUST INCLUDE ALL DELIVERY CHARGES (INCLUDING FREIGHT, PARCEL POST AND EXPRESS) UNLESS OTHERWISE SPECIFIED, FOR PURCHASING MERCHANDISE OR SERVICE DESCRIBED BELOW.

QUOTATIONS WILL BE OPENED IN ACCORDANCE TO RULES AND REGULATIONS ON THE REVERSE SIDE OF THIS SHEET. RESPECTFULLY,

*Gloria J. Goepfer*

QUANTITY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL
		INSTALL ONE (1) MANHOLE AND APPROX. 90LF 12" SCHEDULE 40 PVC PIPE AS FOLLOWS:		
		STARTING AT WET WELL OF THE LIFT STATION AT ENGLE & CLUBVIEW, INSTALL APPROX. 90LF 12" SCHEDULE 40 PVC SEWER PIPE TO THE EAST IN PLACE OF THE EXISTING LINE. SAID NEW LINE TO BE JOINED TO THE SERVICABLE EXISTING LINE BY A PRE-CAST MANHOLE. DEEPEST POINT APPROX. 18' - SOIL CONDITIONS - POOR. NEW LINE TO BE LAID OVER STONE BED SUFFICIENT TO PREVENT SETTLING, SHIFTING OR OTHER MOVEMENT.		
		PRICE TO INCLUDE 100% RESTORATION.		
		CONTRACTORS TO CONTACT BILL KOHRMAN OR JIM BOYCE FOR INFORMATION AND PRIOR TO SUBMITTING BID. (219)427-1255.		
		ALWAYS RETURN THIS COPY OF THE QUOTATION TO THE CITY PURCHASING DEPARTMENT WHETHER OR NOT YOU ACCEPT/DECLINE TO QUOTE.		
		LUMP SUM QUOTE:		
		Sixty-Five Thousand Four Hundred Eighty-Two Dollars		
		TOTAL PRICE <u>65,482.00</u> DELIVERY _____ F.O.B. _____		

**RECEIVED**  
**1988 DEC -5 PM 3:44**  
**PURCHASING**

THIS IS ONLY AN INVITATION TO QUOTE AND NOT AN ORDER. THE ABOVE QUOTES ARE SUBMITTED IN ACCORDANCE WITH THE REGULATIONS ON THE REVERSE SIDE OF THIS SHEET.

SIGNATURE OF BIDDER:

*James E. Bercot*

DATE:

**DECEMBER 5, 1988**

**VENDOR 3**



PLEASE INDICATE THIS NUMBER  
ON ALL CORRESPONDENCE

QUOTE NO. 00 3480

11/16/88

### Quotations

☐ Sealed Bids

WILL BE RECEIVED AT  
THIS OFFICE UNTIL

12/05/88 - 4:00 P.M.

PAGE

The Contractor and his sub-contractors, if any, shall not discriminate against any employee or applicant for employment, to be employed in the performance of this contract, with respect to his hire, tenure, conditions or privileges of employment or any matter directly or indirectly related to employment, because of his race, color, religion, national origin or ancestry. Breach of this covenant may be regarded as a material breach of the contract.

TO

**REQUEST FOR QUOTATION  
THIS IS NOT AN ORDER**

PLEASE QUOTE BELOW LOWEST PRICES, WHICH MUST INCLUDE ALL DELIVERY CHARGES (INCLUDING FREIGHT, PARCEL POST AND EXPRESS) UNLESS OTHERWISE SPECIFIED, FOR PURCHASING MERCHANDISE OR SERVICE DESCRIBED BELOW.

QUOTATIONS WILL BE OPENED IN ACCORDANCE TO RULES  
AND REGULATIONS ON THE REVERSE SIDE OF THIS SHEET.  
RESPECTFULLY,

Gloria J. Goggin

[illegible]

THIS IS ONLY AN INVITATION TO QUOTE AND NOT AN ORDER. THE ABOVE QUOTES ARE SUBMITTED IN ACCORDANCE WITH THE REGULATIONS ON THE REVERSE SIDE OF THIS SHEET.

SIGNATURE OF BIDDER:

Eric S. Olson

DATE: 12/5/88

**VENDOR 3**





City of Fort Wayne  
WPC Maintenance Dept.  
503 E. Wallace  
Fort Wayne, IN 46803

January 10, 1989

ATTENTION: Mr. Bill Kohrman

RE: Engle & Clubview Sanitary Sewer

Dear Bill:

Per our discussions concerning referenced project the following details our construction plans based on our bid of \$17,130.00.

- Install proposed 48" manhole over existing line and place on blocks.
- Cut hole in existing pipe in proposed manhole and pump from this point into lift station.
- Install sewer beginning at first joint west of proposed manhole.
- Terminate sewer at first joint east of subject manhole on west end of new line.

Bill, as discussed we feel there is operating room to open up the ditch to permit safe installation with the use of trench boxes, ~~however, we have not included sheeting or other shoring techniques.~~

Should you have questions or need further information, please call.  
Thank you.

Sincerely,

*Eric S. Olson*

Eric S. Olson  
Marketing Director

ESO:cag

T-G EXCAVATING INC.

5544 Huguenard Road • Fort Wayne, IN 46818

219-489-5541

26016 East Admiral • Catoosa, OK 74015

918-266-4736



BILL NO. S-89-03-20

REPORT OF THE COMMITTEE ON CITY UTILITIES

MARK E. GIAQUINTA, CHAIRMAN  
THOMAS C. HENRY, VICE CHAIRMAN  
LONG, BURNS, TALARICO

WE, YOUR COMMITTEE ON CITY UTILITIES TO WHOM WAS

REFERRED AN (ORDINANCE) (~~RESOLUTION~~) approving the  
awarding of Reference #003480 by the City of Fort Wayne,  
Indiana, by and through its Department of Purchasing and  
JOHN DEHNER for the Water Pollution Control Maintenance  
Department

HAVE HAD SAID (ORDINANCE) (~~RESOLUTION~~) UNDER CONSIDERATION AND  
BEG LEAVE TO REPORT BACK TO THE COMMON COUNCIL THAT SAID

(ORDINANCE)

(~~RESOLUTION~~)

*Withdrawn*


DO PASS

DO NOT PASS

ABSTAIN

NO REC

_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

DATED: 

Sandra E. Kennedy  
City Clerk



## MEMORANDUM

To NATKA ESCHOFF

Date 3-30-89

From GLORIA J. GOEGLIN

Subject BILL NO. S-89-03-20

## COPIES TO:

PLEASE WITHDRAW BILL NO. S-89-03-20. DUE TO A CAVE-IN  
6 FEET IN DIAMETER THE BOARD OF WORKS HAS DECLARED AN  
EMERGENCY RESOLUTION #78-43-9.

PLEASE FIND ATTACHED COPIES OF THE BILL AND THE EMERGENCY  
RESOLUTION.

THANK YOU.



EMERGENCY RESOLUTION 78-43-9

WHEREAS, the sewer line starting at the wet well and running east of Clubview on Engle Road is made of reinforced concrete pipe and deteriorating; and

WHEREAS, this deterioration has caused a cave-in 6 feet in diameter; and

WHEREAS, the rapid advancement of this deterioration could not be easily foreseen; and

WHEREAS, further deterioration in this area could cause serious damage to the lift station located next to the wet well; and

WHEREAS, repair of this line is beyond the capability of the Water Pollution Control Maintenance Department to perform; and

WHEREAS, bids were received from the following:

T & G Excavating	\$17,130.00
John Dehner, Inc.	\$49,840.00
Bercot-Gibson	\$65,482.00

and

WHEREAS, the T & G Excavating bid of \$17,130.00 was rejected because it was open-ended and John Dehner's bid of \$49,840.00 was accepted as they were next low bid firm; and

WHEREAS, approximately 90 LF of 12" Schedule 40 PVC is to be installed starting at the wet well, running east and being joined to the good existing line with a manhole; and

NOW THEREFORE, the Board of Public Works & Safety hereby declares an Emergency exists for said sewer line repair and hereby orders the Purchasing Department to issue an Emergency Purchase Order to John Dehner, Inc., for said repair.

Approved this 29<sup>th</sup> day of March, 1989.

BOARD OF PUBLIC WORKS & SAFETY

Angela S. Derheimer  
Angela S. Derheimer,  
Director of Public Works

C. David Silletto  
C. David Silletto,  
Director of Admn. & Finance

Michael McAlexander  
Michael McAlexander  
Director of Public Safety

Helen V. Gochenour  
Helen V. Gochenour, Clerk



1 BILL NO. S-89-03- 20

2 SPECIAL ORDINANCE NO. S- \_\_\_\_\_

3 AN ORDINANCE approving the awarding of  
4 Reference #003480 by the City of Fort  
5 Wayne, Indiana, by and through its  
6 Department of Purchasing and JOHN DEHNER  
for the Water Pollution Control  
Maintenance Department.

7 NOW, THEREFORE, BE IT ORDAINED BY THE COMMON COUNCIL OF  
8 THE CITY OF FORT WAYNE, INDIANA;

9 SECTION 1. That Reference #003480 between the City of  
10 Fort Wayne, by and through its Department of Purchasing and  
11 JOHN DEHNER for the Water Pollution Control Maintenance  
12 Department, respectfully for:

13 a manhole and sewer line replacement  
14 starting at wet well of the lift station  
at Engle and Clubview;

15 involving a total cost of Forty-Nine Thousand Eight Hundred  
16 Forty and no/100 Dollars (\$49,840.00), all as more  
17 particularly set forth in said Reference #003480 which is  
18 on file in the Office of the Department of Purchasing, and  
19 is by reference incorporated herein, made a part hereof, and  
20 is hereby in all things ratified, confirmed and approved.

21 SECTION 2. That this Ordinance shall be in full force  
22 and effect from and after its passage and any and all  
23 necessary approval by the Mayor.

24  
25 \_\_\_\_\_  
26 Councilmember

27 APPROVED AS TO FORM  
28 AND LEGALITY

29 J. Timothy McCaulay  
30 J. Timothy McCaulay, City Attorney  
31  
32



Read the first time in full and on motion by Paul Helmke, seconded by Jim, and duly adopted, read the second time by title and referred to the Committee on City of Fort Wayne (and the City Plan Commission for recommendation) and Public Hearing to be held after due legal notice, at the Council Conference Room 128, City-County Building, Fort Wayne, Indiana, on \_\_\_\_\_, the \_\_\_\_\_ day of \_\_\_\_\_, 19\_\_\_\_, at \_\_\_\_\_ o'clock \_\_\_\_\_ M., E.S.T.

DATED: 3-27-89

Sandra E. Kennedy  
SANDRA E. KENNEDY, CITY CLERK

Read the third time in full and on motion by \_\_\_\_\_, seconded by \_\_\_\_\_, and duly adopted, placed on its passage. PASSED LOST by the following vote:

	AYES	NAYS	ABSTAINED	ABSENT
TOTAL VOTES				
BRADBURY				
BURNS				
GiaQUINTA				
HENRY				
LONG				
REDD				
SCHMIDT				
STIER				
TALARICO				

DATED: 3-27-89

Sandra E. Kennedy  
SANDRA E. KENNEDY, CITY CLERK

Passed and adopted by the Common Council of the City of Fort Wayne, Indiana, as (ANNEXATION) (APPROPRIATION) (GENERAL) (SPECIAL) (ZONING MAP) ORDINANCE RESOLUTION NO. \_\_\_\_\_

on the \_\_\_\_\_ day of \_\_\_\_\_, 19\_\_\_\_,

ATTEST SEAL

Sandra E. Kennedy  
SANDRA E. KENNEDY, CITY CLERK

\_\_\_\_\_  
PRESIDING OFFICER

Presented by me to the Mayor of the City of Fort Wayne, Indiana, on the \_\_\_\_\_ day of \_\_\_\_\_, 19\_\_\_\_, at the hour of \_\_\_\_\_ o'clock \_\_\_\_\_ M., E.S.T.

Sandra E. Kennedy  
SANDRA E. KENNEDY, CITY CLERK

Approved and signed by me this \_\_\_\_\_ day of \_\_\_\_\_, 19\_\_\_\_, at the hour of \_\_\_\_\_ o'clock \_\_\_\_\_ M., E.S.T.

Paul Helmke  
PAUL HELMKE, MAYOR



DIGEST SHEET

TITLE OF ORDINANCE: Special

*89-03-20*

DEPARTMENT REQUESTING ORDINANCE: Purchasing

SYNOPSIS OF ORDINANCE: An ordinance approving the award of Reference No. 3480 with respect to the replacement of a manhole and sewer line for the WPC Maintenance Department. The cost reflects the most responsible of three (3) vendors.

EFFECT OF PASSAGE: Install 90lf 12" schedule 40 PVC sewer pipe to wet well and connect to existing serviceable line by a pre-cast manhole-pour soil-18' at deepest. 100% restoration-stone bed to be placed in as base.

EFFECT OF NON-PASSAGE: Further deterioration of line, possible damage to lift station pumps.

MONIES INVOLVED: John Dehner \$49,840.00

SOURCE OF FUNDING: WPC Maintenance  
514-532-M711-4364

PRIOR APPROVAL:  
(IF APPLICABLE)

DATE: